

¹ ENVIRONMENTAL TEST CERTIFICATE

- 2 Certificate No.: TES-004150-16-02 Product : 3 Weatherproof Electrical Connection Box 4 Model / Type Ref.: 285 & 330 5 Name and address of DRi BOX Ltd., the applicant: Disklok House, Preston Road, Charnock Richard, Lancashire, PR7 5HH, United Kingdom. DRi BOX Ltd., 6 Name and address of the manufacturer: Disklok House, Preston Road, Charnock Richard, Lancashire, PR7 5HH, United Kingdom.
- 7 TRaC Global Ltd confirms that a sample of this equipment (as described within the schedule to this certificate) has been found to comply with the requirements of the test standards listed in section 8 below.

Report re-issued to incorporated change of applicants name.

The examination and test results are recorded in the confidential report TES-004150-16-01.

8 Compliance has been assured by compliance with:

EN60529:1991/A1:2000 (IP55)

- 9 This certificate of conformity is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard. It does not imply an assessment of the whole production and does not permit the use of a mark of conformity.
- 10 This certificate may only be reproduced in its entirety and without change.

S.P. Winsor, Certification Officer Issue date: 2012-07-11

Page 1 of 2

NORTH WEST

Unit 1, Pendle Place, Skelmersdale, West Lancashire, WN8 9PN UK. T +44 (0)1695 556666 F +44 (0)1695 557077 E test@tracglobal.com www.tracglobal.com 51F063A is08



SCHEDULE TO CERTIFICATE TES-004150-16-02

General description of equipment or protective system included within the scope of this certificate

DRiBOX is a weatherproof plastic enclosure which houses four way mains extension leads to power mains operated electrical equipment in an outdoor environment.

The equipment is available in two models, 285 and 330 which relate directly to their size in millimetres. The cable ports and lid sealing methods are identical for both models.

Photographic record of equipment tested

